

Extension
Certificate

Manufacturer: **Kyocera Corporation**
Solar Energy Division33
6 Takeda Tobadono-Cho
Fushimi-Ku, Kyoto
612-8501 Japan

Product: **PV Modules**
Type: KC35, KC45, KC50, KC60H, KC70

The product was tested voluntarily according to technical regulations.

The product mentioned above complies with the
requirements on
Safety Class II equipment
and may be used in plants at a total voltage of up to

750 VDC


The testing principles are documented in detail in the test report
No. 931/129 013B


Remarks:

1. The above mentioned module types have been developed from the module type KC40 and KC80.
Constructional changes: Cell size, number of cells and outer dimensions of the modules.
2. The certificate is only valid in conjunction with proof of the mechanical suitability of the modules in accordance with IEC 61215 (or similar procedure).
3. Any change to the design, materials, components or processing may require repetition of some of the qualification tests in order to retain type approval.

This certificate is valid through September 2003

Date: September 01, 2000


Testzentrum Energietechnik


Regenerative Energien